SIEMENS

Data sheet

6ES7518-4AP00-0AB0



SIMATIC S7-1500, CPU 1518-4 PN/DP, central processing unit with 6 MB work memory for program and 60 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface: PROFINET RT, 3rd interface: Ethernet, 4th interface: PROFIBUS, 1 ns bit-performance, SIMATIC Memory Card required

General information	
Product type designation	CPU 1518-4 PN/DP
HW functional status	FS10
Firmware version	V2.9
Product function	
 I&M data 	Yes; I&M0 to I&M3
Isochronous mode	Yes; Distributed and central; with minimum OB 6x cycle of 125 μs (distributed) and 1 ms (central)
Engineering with	
 STEP 7 TIA Portal configurable/integrated from version 	V17 (FW V2.9) / V13 (FW V1.5) or higher
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	6.1 cm
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	1.55 A
Inrush current, max.	2.4 A; Rated value
l²t	0.02 A ² ·s
Power	
Infeed power to the backplane bus	12 W
Power consumption from the backplane bus (balanced)	30 W
Power loss	
Power loss, typ.	24 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
 integrated (for program) 	6 Mbyte

 integrated (for data) 	60 Mbyte
Load memory	
 Plug-in (SIMATIC Memory Card), max. 	32 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	1 ns
for word operations, typ.	2 ns
for fixed point arithmetic, typ.	2 ns
for floating point arithmetic, typ.	6 ns
CPU-blocks	
	20,000: Plooks (OR, ER, EC, DR) and UDTs
Number of elements (total) DB	20 000; Blocks (OB, FB, FC, DB) and UDTs
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max. FB	16 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
Number range	0 65 535
• Size, max.	1 Mbyte
FC	
Number range	0 65 535
• Size, max.	1 Mbyte
OB	
• Size, max.	1 Mbyte
 Number of free cycle OBs 	100
Number of time alarm OBs	20
 Number of delay alarm OBs 	20
Number of cyclic interrupt OBs	20; with minimum OB 3x cycle of 100 µs
 Number of process alarm OBs 	50
Number of DPV1 alarm OBs	3
Number of isochronous mode OBs	3
Number of technology synchronous alarm OBs	2
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	-
Nesting depth	·
 per priority class 	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	Any (only infliced by the main memory)
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	, (, , , , , , , , , , , , , , , , , ,
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	768 kbyte; In total; available retentive memory for bit memories, timers,
Extended retentive data area (incl. timers, counters, flags),	counters, DBs, and technology data (axes): 700 KB 20 Mbyte; When using PS 6 0W 24/48/60 V DC HF
max.	
Flag	
Size, max.	16 kbyte
 Number of clock memories 	8; 8 clock memory bit, grouped into one clock memory byte

Data blocks	
Retentivity adjustable	Yes
Retentivity preset	No
Local data	
 per priority class, max. 	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	16 384; max. number of modules / submodules
I/O address area	
Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4
— Outputs (volume)	32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4
per CM/CP	014-4-
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images Number of subprocess images, max. 	32
Hardware configuration	
	64: A distributed 1/0 system is sharestarized ast ask by the integration
Number of distributed IO systems	64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
integrated	1
● Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Number of IO Controllers	
integratedVia CM	2 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	
 Modules per rack, max. 	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
•Туре	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter Number	16
Clock synchronization	
• supported	Yes
• to DP, master	Yes
• in AS, master	Yes
• in AS, slave	Yes
 on Ethernet via NTP 	Yes
Interfaces	
Number of PROFINET interfaces	3
Number of PROFIBUS interfaces	1
1. Interface	
Interface types	
RJ 45 (Ethernet)	Yes; X1
Number of ports	2
integrated switch	Yes
Protocols	
• IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device SIMATIC communication	Yes
SIMATIC communication	Yes Ves: Ontionally also encrypted
Open IE communication	Yes; Optionally also encrypted

Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
 — Isochronous mode 	Yes
 — Direct data exchange 	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
 Prioritized startup 	Yes; Max. 32 PROFINET devices
— Number of connectable IO Devices, max.	512; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
 — Of which IO devices with IRT, max. 	64
 Number of connectable IO Devices for RT, 	512
max.	540
— of which in line, max.	512 Stin total across all interfaces
 — Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
-	8
 Number of IO Devices per tool, max. 	
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 125 µs	125 µs
— for send cycle of 187.5 μs	187.5 µs
— for send cycle of 250 μs	250 µs to 4 ms
— for send cycle of 500 µs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd" send	Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625
cycles	μs 3 875 μs)
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 μs	500 µs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
	Yes
— PG/OP communication	
— Isochronous mode	No Yea: Minimum cond cyclo of 250 up
— IRT	Yes; Minimum send cycle of 250 µs
— PROFlenergy	Yes; per user program
— Shared device	Yes
 Number of IO Controllers with shared device, 	4
max.	
 activation/deactivation of I-devices 	Yes; per user program
— Asset management record	Yes; per user program
2. Interface	
Interface types	
RJ 45 (Ethernet)	Yes; X2
Number of ports	1
integrated switch	No
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	No
PROFINET IO Controller	
Services	Vec
— PG/OP communication	Yes

 — Isochronous mode 	No
— Direct data exchange	No
— IRT	No
— PROFlenergy	Yes; per user program
— Prioritized startup	No
— Number of connectable IO Devices, max.	128; In total, up to 1 000 distributed I/O devices can be connected via
- Number of connectable IO Devices for RT,	AS-i, PROFIBUS or PROFINET 128
max.	120
— of which in line, max.	128
— Number of IO Devices that can be	
simultaneously activated/deactivated, max.	8; in total across all interfaces
 — Number of IO Devices per tool, max. 	8
— Updating times	The minimum value of the update time also depends on communication
- Opdaling limes	share set for PROFINET IO, on the number of IO devices, and on the
	quantity of configured user data
Update time for RT	
— for send cycle of 1 ms	1 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	No
— PROFlenergy	Yes; per user program
— Prioritized startup	No
 — Shared device 	Yes
 — Number of IO Controllers with shared device, 	4
max.	
 — activation/deactivation of I-devices 	Yes; per user program
 Asset management record 	Yes; per user program
3. Interface	
Interface types	
• RJ 45 (Ethernet)	Yes; X3
Number of ports	1
Number of portsintegrated switch	
Number of ports integrated switch Protocols	1 No
Number of ports integrated switch Protocols IP protocol	1 No Yes; IPv4
Number of ports integrated switch Protocols IP protocol PROFINET IO Controller	1 No Yes; IPv4 No
Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device	1 No Yes; IPv4 No No
Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication	1 No Yes; IPv4 No No Yes
Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device	1 No Yes; IPv4 No No
Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication	1 No Yes; IPv4 No No Yes
Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication	1 No Yes; IPv4 No No Yes Yes
Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface	1 No Yes; IPv4 No No Yes Yes
Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server	1 No Yes; IPv4 No No Yes Yes Yes Yes
Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485	1 No Yes; IPv4 No No Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports 	1 No Yes; IPv4 No No Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols 	1 No Yes; IPv4 No No Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master PROFIBUS DP master Number of connections, max. 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes No Yes No Yes A8; for the integrated PROFIBUS DP interface
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes Yes A8; for the integrated PROFIBUS DP interface 125; In total, up to 1 000 distributed I/O devices can be connected via
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master PROFIBUS DP master Number of connections, max. Number of DP slaves, max. 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes No Yes No Yes A8; for the integrated PROFIBUS DP interface
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master Number of connections, max. Number of DP slaves, max. 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes 48; for the integrated PROFIBUS DP interface 125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master PROFIBUS DP master Number of connections, max. Number of DP slaves, max. Services — PG/OP communication 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes A Asi, for the integrated PROFIBUS DP interface 125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master PROFIBUS DP master PROFIBUS DP master PROFIBUS DP master Number of connections, max. Number of DP slaves, max. Services PG/OP communication Equidistance 	1 No Yes; IPv4 No No No Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master Number of connections, max. Number of DP slaves, max. Services PG/OP communication Equidistance Isochronous mode 	1 No Yes; IPv4 No No No Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master PROFIBUS DP master PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master Number of connections, max. Number of DP slaves, max. Services PG/OP communication Equidistance 	1 No Yes; IPv4 No No No Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master Number of connections, max. Number of DP slaves, max. Services PG/OP communication Equidistance Isochronous mode 	1 No Yes; IPv4 No No No Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP slave SIMATIC communication PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP slave SIMATIC communication PROFIBUS DP master Interface of the protect of th	1 No Yes; IPv4 No No No Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master PROFIBUS DP master PROFIBUS DP master Number of connections, max. Number of DP slaves, max. Services — PG/OP communication — Equidistance — Isochronous mode — Activation/deactivation of DP slaves Interface types RJ 45 (Ethernet)	1 No Yes; IPv4 No No No Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master Number of connections, max. Number of DP slaves, max. Services — PG/OP communication — Equidistance — Isochronous mode — Activation/deactivation of DP slaves Interface types RJ 45 (Ethernet) 100 Mbps 	1 No Yes; IPv4 No No Yes Yes Yes Yes Yes No Yes 48; for the integrated PROFIBUS DP interface 125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET Yes Yes Yes Yes
 Number of ports integrated switch Protocols IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server 4. Interface Interface types RS 485 Number of ports Protocols PROFIBUS DP master PROFIBUS DP slave SIMATIC communication PROFIBUS DP master PROFIBUS DP master PROFIBUS DP master Number of connections, max. Number of DP slaves, max. Services — PG/OP communication — Equidistance — Isochronous mode — Activation/deactivation of DP slaves Interface types RJ 45 (Ethernet)	1 No Yes; IPv4 No No Yes

	Vac
Autocrossing	Yes
Industrial Ethernet status LED RS 485	Yes
	12 Mbit/s
• Transmission rate, max.	
Protocols	
PROFIsafe	No
Number of connections	
 Number of connections, max. 	384; via integrated interfaces of the CPU and connected CPs / CMs
 Number of connections reserved for ES/HMI/web 	10
 Number of connections via integrated interfaces 	320
 Number of S7 routing paths 	64; in total, only 16 S7-Routing connections are supported via PROFIBUS
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— Media redundancy	only via 1st interface (X1)
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client
- MRP interconnection, supported	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
— Switchover time on line break, typ.	200 ms; For MRP, bumpless for MRPD
- Number of stations in the ring, max.	50
SIMATIC communication	
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
S7 routing	Yes
Data record routing	Yes
S7 communication, as server	Yes
 S7 communication, as server S7 communication, as client 	Yes
User data per job, max. Open IE communication	See online help (S7 communication, user data size)
TCP/IP	Yes
— Data length, max.	64 kbyte
 — several passive connections per port, supported 	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte: 1 472 bytes for UDP broadcast
— UDP multicast	Yes; 128 multicast circuits (of which max. 5 via X1)
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
ELDF Encryption	Yes; Optional
• Encryption Web server	
HTTP	Yes; Standard and user pages
• HTTPS	
OPC UA	Yes; Standard and user pages
	Ves: "Large" license required
 Runtime license required OPC UA Client 	Yes; "Large" license required
	Yes Yes
 Application authentication Security policies 	Available security policies: None, Basic128Rsa15, Basic256Rsa15,
	Basic256Sha256
— User authentication	"anonymous" or by user name & password
— Number of connections, max.	40
 number of nodes of the client interfaces, recommended max 	5 000
recommended max.	200
 — Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/C max. 	300
 Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. 	20
— Number of elements for one call of	100
OPC_UA_MethodGetHandleList, max.	

 number of simultaneous calls of the client instructions for session management, per connection, max. 	1
 number of simultaneous calls of the client instructions for data access, per connection, max. 	5
 — Number of registerable nodes, max. 	5 000
 — Number of registerable method calls of OPC_UA_MethodCall, max. 	100
 — Number of inputs/outputs when calling OPC_UA_MethodCall, max. 	20
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
 — User authentication 	"anonymous" or by user name & password
 — GDS support (certificate management) 	Yes
 — Number of sessions, max. 	64
 — Number of accessible variables, max. 	200 000
 Number of registerable nodes, max. 	50 000
 — Number of subscriptions per session, max. 	20
 — Sampling interval, min. 	10 ms
— Publishing interval, min.	10 ms
 — Number of server methods, max. 	100
 — Number of inputs/outputs per server method, max. 	20
 number of monitored items, recommended max. 	10 000; for 1 s sampling interval and 1 s send interval
— Number of server interfaces, max.	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
 — Number of nodes for user-defined server interfaces, max. 	30 000
 Alarms and Conditions 	Yes
 — Number of program alarms 	400
 — Number of alarms for system diagnostics 	200
Further protocols	
MODBUS	Yes; MODBUS TCP
	Yes; MODBUS TCP
MODBUS	Yes; MODBUS TCP Yes
MODBUS Isochronous mode	
MODBUS Isochronous mode Equidistance S7 message functions	
MODBUS Isochronous mode Equidistance	Yes
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max.	Yes 64
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm"
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max.	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max.	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commission (Team Engineering)	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of loadable program alarms Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients)
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of loadable program alarms Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of simultaneously active program alarms Number of program alarms	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block Single step Number of breakpoints 	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program messages in RUN, max. Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering)	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. 	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
 MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control variable Variables Number of variables, max. — of which status variables, max. 	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job
 MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max. 	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
 MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of simultaneously active program alarms Number of program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. of which control variables, max. 	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job
 MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max.	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job
 MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block Single step Number of variables Variables Number of variables, max. of which status variables, max. of which control variables, max. of which status variables, max. of which status variables, max.	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job
 MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max.	Yes 64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job

	Vec
present Number of entries, max	Yes 3 200
 Number of entries, max. — of which powerfail-proof 	1 000
Traces	1 000
Number of configurable Traces	8; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED • RUN/STOP LED	Yes
ERROR LED	Yes
MAINT LED	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
	Very Nate: The number of technology chicate affects the syste time of
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
 Number of available Motion Control resources for 	15 360
technology objects	
 Required Motion Control resources 	
 per speed-controlled axis 	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
 Positioning axis 	
 Number of positioning axes at motion control 	140
cycle of 4 ms (typical value)	400
 — Number of positioning axes at motion control cycle of 8 ms (typical value) 	192
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
• PID_3Step	Yes; PID controller with integrated optimization for valves
• PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	0°C
 horizontal installation, max. 	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the
	display is switched off
 vertical installation, min. 	0 °C
 vertical installation, max. 	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the
	display is switched off
Ambient temperature during storage/transportation	
● min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— GRAPH	Yes
Know-how protection	
 User program protection/password protection 	Yes
Copy protection	Yes
Copy protectionBlock protection	Yes Yes
Copy protection Block protection Access protection	Yes
Copy protection Block protection Access protection protection of confidential configuration data	Yes Yes
Copy protection Block protection Access protection	Yes

 Protection level: Read/write protection 	Yes
 Protection level: Complete protection 	Yes
programming / cycle time monitoring / header	
lower limit	adjustable minimum cycle time
upper limit	adjustable maximum cycle time
Dimensions	
Width	175 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	1 988 g

last modified:

4/1/2022 🖸